



*The National Floor Safety Institute*  
P.O. Box 92628  
Southlake, TX 76092  
(817) 749-1700 FAX (817) 749-1702  
[www.nfsi.org](http://www.nfsi.org)

September 22, 2003

Mr. Greg Schwietz  
President  
L&M Construction Chemicals, Inc.  
14851 Calhoun Rd.  
Omaha, NE 68152

Dear Mr. Schwietz;

Congratulations! The material you have submitted for phase two testing has passed and is now certified as "High-Traction". The FGS PermaShine process and liquid hardener (FGS Hardener Plus) material were installed on a concrete floor in a commercial facility for a period of 30 days, cleaned and tested under NFSI test method 101-A. Our on-site examination revealed Static Coefficient of Friction (SCOF) values greater than a 0.6 and therefore has passed our phase two level of certification.

Attached is an electronic version of the NFSI Certified logo to which you are granted permission to attach to the FGS PermaShine product label, sales literature, website, etc. Again, congratulations and thank you for submitting your product to the NFSI.

Regards,

Russell J. Kendzior  
Executive Director

RJK/nm